

CERTIFICATE OF COMPLIANCE

Certificate Number 20130723- E12629
Report Reference E12629-20060517
Issue Date 2013-JULY-23

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484

This is to certify that representative samples of AUDIBLE-SIGNAL APPLIANCES FOR USE IN HAZARDOUS LOCATIONS
See addendum page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 464, Standard for Safety for Audible Signal Appliances. ANSI/ISA 12.12.01, Standard for Non-incendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations C22.2 No. 205-M1983 and C22.2 No. 213-M1987, Standard for Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations C22.2 No 157-92, Standard for Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and

"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130723- E12629
Report Reference E12629-20060517
Issue Date 2013-JULY-23

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL-1,CNL Audible Signal Appliances, General Signaling, For Use In Hazardous Locations, Models 300GCX and 302GCX when used with Federal Signal's Listed (UGKZ, UGKZC) plug-in module, Model TC-HL, -HN, -WL, -YP -YW, TM2, UTC or UTM; or Listed (UGKZ, UGKZ7) plug-in module, Model TM33. Hazardous Locations, Class I, Division 2, Groups A, B, C, and D; Class II, Division 2, Groups F and G; and Class III; Suitable for Outdoor Use;

USL-2,CNL Signaling Speaker, General Signaling, For Use In Hazardous Locations, Models 300GCX and 302GCX when used with Federal Signal's Listed (UGKZ, UGKZ7) plug-in module, Model 300CK, 300CKS, AM25CK, AM70CK, CK25, CK70, E-300CK, EM3 or T-300CK. Hazardous Locations, Class I, Division 2, Groups A, B, C, and D; Class II, Division 2, Groups F and G; and Class III; Suitable for Outdoor Use;



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

