

CERTIFICATE OF COMPLIANCE

Certificate Number 20130723- E12629
Report Reference E12629-20060223
Issue Date 2013-JULY-23

Issued to: FEDERAL SIGNAL CORP SIGNAL DIV
2645 FEDERAL SIGNAL DR
UNIVERSITY PARK IL 60484

This is to certify that representative samples of AUDIBLE-SIGNAL APPLIANCES FOR USE IN HAZARDOUS LOCATIONS
See addendum page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1203, Standard for Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous Locations.
ANSI/ISA 12.12.01, Standard for Non-incendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations.
C22.2 No. 0, C22.2 No. 0.4, C22.2 No. 30, Standard for Explosion-Proof Enclosures for Use in Class I Hazardous Locations.
C22.2 No. 157, Standard for Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations
C22.2 No. 213 Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations .
ULC Standard ULC-S525-07 Standard for Audible Signal Devices For Fire Alarm Systems Including Accessories

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130723- E12629
Report Reference E12629-20060223
Issue Date 2013-JULY-23

Look for the UL Listing Mark on the product.

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL-1, CNL - Audible Signal Appliances For General Service (Non-Fire) For Use In Hazardous Locations, Models 300X and 302X when used with Federal Signal's Listed (UGKZ/UGKZ7) plug-in module, Models TC-HL, -HN, -WL, -YP, -YW, TM2, TM33, UTC, or UTM. Hazardous Locations, Class I, Division 1, Groups B, C, and D; Class I, Division 2, Groups A, B, C, and D; Class II, Division 2, Groups F and G; and Class III; Suitable for Indoor/Outdoor Use.

USL-2, CNL - Signaling Speaker For General Service (Non-Fire) For Use In Hazardous Locations, Models 300X and 302X when used with Federal Signal's Listed (UGKZ/UGKZ7) plug-in module, Models EM3, 300CK, E-300CK, T-300CK, 300CKS, AM25CK, AM70CK, CK25, or CK70. Hazardous Locations, Class I, Division 1, Groups B, C, and D; Class I, Division 2, Groups A, B, C, and D; Class II, Division 2, Groups F and G; and Class III; Suitable for Indoor/Outdoor Use.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

