

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	7136-0811:0505
CATEGORY:	7136 - AUDIBLE DEVICES FOR HAZARDOUS LOCATIONS
LISTEE:	Federal Signal 2645 Federal Signal Drive, University Park, IL, 60466 Contact: Moloney, Sean 7085873324 Email: smoloney@federalsignal.com
DESIGN:	Global Series Models G-SND Sounder Series, G-SPK Loudspeaker Series, and G-SPA Amplified Speaker Series, Listed audible devices for use in Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G; Class III locations.
	G Series Sounder, Model G-SND; followed by -MV, -024, -120, or -230; may be followed by -E, -D, or -T.
	G Series Loudspeaker, Model G-SPK; followed by -070 or -100; may be followed by -E, -D or -T.
	G Series Amplified Speaker, Model G-SPA; may be followed by -MV; may be followed by -024; may be followed by -120; may be followed by -230; may be followed by -E, -D, or -T; may be followed by -25V.
	Refer to listee's data sheet for additional detailed product description and operational considerations.



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

RATING:	G-SND
	24 VDC Regulated (16-33 VDC), 515 mA
	24 VDC, 370 mA
	110 VAC, 200 mA
	240 VAC, 80 mA
	G-SPK
	70 VAC, 15W, 10W, 7W, 2W, 1.5W, 1.0W, 0.75W,
	0.5W, 0.25W
	100 VAC, 15W, 10W, 7W, 2W, 1.5W, 1.0W, 0.75W,
	0.5W, 0.25W
	G-SPA
	24 VDC, 370 mA
	110 VAC, 200 mA
	240 VAC, 60 mA
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as a fire alarm's audible devices for use with separately listed electrically compatible fire alarm control unit. Listed audible devices for use in Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G; Class III hazardous locations. Refer to listee's Installation Instructions Manual for details. These devices met the requirements of UL 1480.
NOTES:	

12-22-23 bh



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/18/2024 Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator Fire Engineering & Investigations Division